

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF AUXIER WATER CO., )	
INC. FOR A DEVIATION PURSUANT TO 807 )	
KAR 5:066, SECTION 5(4), REGARDING )	CASE NO. 91-414
WATER STORAGE )	

O R D E R

By application received November 7, 1991, Auxier Water Company, Inc. ("Auxier Water") requested a deviation from Commission Regulation 807 KAR 5:066, Section 5(4), which provides that each utility shall provide water storage to ensure a minimum of one day's supply of its average daily water usage. Auxier Water states in its application that it has employed a consulting engineering firm, which is to prepare a plan for the construction and financing of additional water storage facilities to comply with Commission Regulation 807 KAR 5:066, Section 5(4). Auxier Water also states in its application that it should be in compliance with Commission Regulation 807 KAR 5:066, Section 5(4), within 5 years.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Auxier Water is not in compliance with Commission Regulation 807 KAR 5:066, Section 5(4).

2. Because of the time needed to plan, finance, and implement a program to construct water storage facilities, Auxier Water should be given until July 1, 1996 to bring it within compliance of Commission Regulation 807 KAR 5:066, Section 5(4).


IT IS THEREFORE ORDERED that:

1. Auxier Water be and it hereby is given until July 1, 1996 to comply with the provisions of 807 KAR 5:066, Section 5(4).


2. Auxier Water shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to July 1, 1996.

Done at Frankfort, Kentucky, this 23rd day of December, 1991.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

  
Executive Director